

2021 Greater Philadelphia RV Show

Important Notes

All LPG/CNG cylinders are prohibited within the building.

Motorized Vehicles

At least one battery cable shall be disconnected and taped to prevent contact with the battery terminal.

Fuel tank must have no more than 1/4 of capacity **or** 5 gallons, whichever is less.

Ignition key must be left in vehicle until checked by the Fire Marshal.

All fuel tank openings shall be locked or sealed in an approved manner to prevent escape of vapors. Where it is not feasible to seal or lock the opening, the tank will be emptied. Draining of the tank shall not occur within the building.

No vehicle with a combustion engine of any kind may be started during show hours.

Please read the complete Convention Center Fire Safety Regulations on our web site; www.phillyrvshow.com.